# Sample Report

# **Test Information**

Test Date:	Thursday, Novembe 17, 2011	<sup>r</sup> Engineer:	John Smith	Bay:	Load Test Bay 1
Customer:	Acme	Job #:	12345-67-89		
Genset					
Model: abc123	Series:	123			
Rating					
kW:	300.00	kVA:	400.00	Volts L-N:	277.00
Volts L-L:	480.00	Amps:	480.00	PF:	0.800
Phase:	3	Hz:	60.00	RPM:	1800.00
Engine					
Manufacturer:	ABC123	Serial #:	98765-43-21	Model:	123456
Fuel Type:	Diesel	Governor:	DEF456	Controller:	HIJ789
Generator					
Manufacturer:	Marathon Electric	Serial #:	654321	Model:	123
Connection:	Delta	Wires:	Other	Leads:	3
Test Setting	S				
Transients					
Voltage Max + D	eviation:	15.00%	Frequency Max +	Deviation:	15.00%
Voltage Max - Deviation:		-5.00%	Frequency Max -	Frequency Max - Deviation:	
Voltage Dip Recoverv Time:		5.00 sec.	Frequency Dip R	ecovery Time:	5.00 sec.
Voltage Rise Recovery Time:		5.00 sec.	Frequency Rise Recovery Time:		5.00 sec.
Steady State					
Voltage Max + D	eviation:	2.00%	Frequency Max +	Deviation:	0.50%
Voltage Max - Deviation:		-2 00%	Frequency Max - Deviation:		-0.50%

# **Step Results**

## Step 1

Time:	15.0 sec	<b>kW:</b> 25.00	<b>kVAR:</b> 18.75
	10.0 000	RUIT 20.00	

<u>Vab (484.8)</u>













#### <u>kW (25.1)</u>





## Transients

Voltage Max + Deviation:	0.8%	PASS	Frequency Max + Deviation:	0.1%	PASS
Voltage Max - Deviation:	0.4%	PASS	Frequency Max - Deviation:	2.0%	PASS
Voltage Dip Recovery Time:	0.0sec.	PASS	Frequency Dip Recovery Time:	1.0sec.	PASS
Voltage Rise Recovery Time:	0.0sec.	PASS	Frequency Rise Recovery Time:	0.0sec.	PASS
Steady States					

Voltage Max + Deviation:	1.0%	PASS	Frequency Max + Deviation:	0.0%	PASS
Voltage Max - Deviation:	0.8%	PASS	Frequency Max - Deviation:	0.1%	PASS

#### Step 2

Time: 15.0 sec

kVAR: 37.50





**kW:** 50.00









0



#### <u>kW (50.1)</u>





10

15

20

5

#### Transients

Voltage Max + Deviation:	0.8%	PASS	Frequency Max + Deviation:	0.1%	PASS
Voltage Max - Deviation:	0.3%	PASS	Frequency Max - Deviation:	1.4%	PASS
Voltage Dip Recovery Time:	0.0sec.	PASS	Frequency Dip Recovery Time:	0.9sec.	PASS
Voltage Rise Recovery Time:	0.0sec.	PASS	Frequency Rise Recovery Time:	0.0sec.	PASS

#### **Steady States**

Voltage Max + Deviation:	1.0%	PASS	Frequency Max + Deviation:	0.0%	PASS
Voltage Max - Deviation:	0.8%	PASS	Frequency Max - Deviation:	0.1%	PASS

#### Step 3



Vab (485.2)

Vac (480.4)

## Sample Report Acme















Vavg (485.2)







#### <u>kvar (18.8)</u>



# <u>kW (25.1)</u>







## Sample Report Acme



Voltage Max + Deviation:	1.2%	PASS	Frequency Max + Deviation:	0.1%	PASS
Voltage Max - Deviation:	0.8%	PASS	Frequency Max - Deviation:	0.1%	PASS